

Trustees:
Robert A. Emmons, President
Richard H. Littlefield, Vice President
James E. Burrows
Thomas P. Oliver

Kennebunk, Kennebunkport and Wells Water District

Normand R. Labbe, Superintendent
Scott J. Minor, Assistant Superintendent
Wayne A. Brockway, Treasurer

P.O. Box 88, 92 Main Street
Kennebunk, Maine 04043

Phone 207-985-3385
Fax 207-985-3102
www.kkw.org

January 5, 2018

Lydia Mather
Caleb Johnson Studio
110 Exchange Street 2nd Floor
Portland ME 04101

Subject: 222 sq.ft. addition including 1 bathroom and increased seating to 80.

Dear Ms. Mather:


This letter is to inform you that near the above location an adequate domestic water supply is available from the District's 16" water main along Post Road (Route One). Water pressure in this area typically averages approximately 60 PSI. For fire suppression purposes approximately 1000 gallons per minute at 40 PSI residual pressure is available along Route One near this location. This figure is an estimate for planning purposes only. An actual field test should be performed by the owner's agent prior to designing any fire suppression system.

The owner may be assessed an appropriate share of the costs of system expansion which will include but may not be limited to a System Development Charge, based upon meter size and/or anticipated water consumption, as approved by the Maine Public Utilities Commission.

The property is currently one unit served by a 1" service line and 5/8" meter. If new units are added or upgraded service is needed to meet any additional demand that may result from this change of use, the owner will be allowed to request one pursuant to the District's rules and regulations in effect at that time.

If you need any additional information, feel free to call.

Sincerely,



Paul Cote
Assistant Distribution Manager