

Town of Wells, Maine
Preliminary Major Subdivision Plan Completeness Review
Page 1 of 7

Project Name/Map & Lot #: Hobbs Pond Woods- Tax Map 62, Lot 11-A-1

Prepared By: Planning Office

Plans Dated: 3/22/19; 4/16/19

District: R and ShO

Review Date: 4/2/19; 4/30/19

Prelim. Plan Revisions Submittal Date: 4/26/19

Chapter 202
Subdivision of Land

§ 202- 8. Preliminary Plan for Major Subdivision		Application Meet Requirements				
		Yes	No	NA	Waiver	Comments
B.	Submissions:					
	(1) Location map. The preliminary plan shall be accompanied by a location map adequate to show the relationship of the proposed subdivision to the adjacent properties and to allow the Board to locate the subdivision within the municipality. The location map shall show:	Y				Location Maps provided.
	(a) Existing subdivisions adjacent to the proposed subdivision.	Y				Adjacent subdivisions are noted (Meetinghouse Woods Subdivision, Meeting Place Estates Subdivision, Burnt Mill Estates Subdivision).
	(b) Locations and names of existing and proposed streets.	Y				Location map labels Burnt Mill Road, Route 109 and Meetinghouse Road.
	(c) Boundaries and designations of zoning districts.	Y				The Rural zone and 75' Shoreland Overlay Zone are noted. Location map does identifies zoning (Rural and Residential A zone)
	(d) An outline of the proposed subdivision and any remaining portion of the owner's property if the preliminary plan submitted covers only a portion of the owner's entire contiguous holding.	Y				Subdivision Open Space is labelled.

Town of Wells, Maine
Preliminary Major Subdivision Plan Completeness Review
Page 2 of 7

Project Name/Map & Lot #: Hobbs Pond Woods- Tax Map 62, Lot 11-A-1

Prepared By: Planning Office

Plans Dated: 3/22/19; 4/16/19

District: R and ShO

Review Date: 4/2/19; 4/30/19

Prelim. Plan Revisions Submittal Date: 4/26/19

§ 202- 8. Preliminary Plan for Major Subdivision	Application Meet Requirements				
	Yes	No	NA	Waiver	Comments
<p>(2) Preliminary plan. The preliminary plan shall be submitted in three copies of one or more maps or drawings which may be printed or reproduced on paper, with all dimensions shown in feet or decimals of a foot. The preliminary plan shall be drawn to a scale of not more than 100 feet to the inch. The Board may allow plans for subdivisions containing more than 100 acres to be drawn at a scale of not more than 200 feet to the inch provided all necessary detail can easily be read. In addition, the applicant shall submit to the Office of Planning and Development 11 copies of the plan(s) reduced to a size of 11 inches by 17 inches and all accompanying information assembled into a booklet no less than 10 days prior to the meeting. The following information shall either be shown on the preliminary plan or accompany the application for preliminary approval: [Amended 4-12-1999]</p>	Y				<p>Plan scale is 1" = 100 feet on sheet 1 and 2. And 1" = 40 feet on sheet 3.</p>
<p>(a) The proposed name of the subdivision and the name of the municipality in which it is located, plus the Tax Assessor's map and lot numbers.</p>	Y				<p>Note 6 states the existing Map and Lot number (Lot 11-A-1 and states the proposed Map and Lot numbers of the cluster lots.</p>
<p>(b) An actual field survey of the boundary lines of the tract, giving complete descriptive data by bearings and distances, made and certified by a licensed land surveyor. The corners of the tract shall be located on the ground and marked by monuments. The plan shall indicate the type of monument set or found at each lot corner.</p>	Y				<p>Plan prepared and stamped by Robert C. Libby, PLS #2190 of BH2M dated Jan 2019, revised 3/22/19.</p> <p>Existing and proposed monument types noted.</p>
<p>(c) A copy of the deed from which the survey was based and a copy of all covenants or deed restrictions, easements, rights-of-way or other encumbrances currently affecting the property.</p>	Y*				<p>Deeds provided: Book 17810, Page 236 and Book 2595, Page 79.</p> <p>An HOA shall be established to own and maintain the street and open space. See note 19.</p> <p><u>Town Engineer and Town Attorney shall review the Declaration/Homeowners Association documents and sample deed at the time of final application review.</u></p>

Town of Wells, Maine
Preliminary Major Subdivision Plan Completeness Review
Page 3 of 7

Project Name/Map & Lot #: Hobbs Pond Woods- Tax Map 62, Lot 11-A-1

Prepared By: Planning Office

Plans Dated: 3/22/19; 4/16/19

District: R and ShO

Review Date: 4/2/19; 4/30/19

Prelim. Plan Revisions Submittal Date: 4/26/19

§ 202- 8. Preliminary Plan for Major Subdivision		Application Meet Requirements				
		Yes	No	NA	Waiver	Comments
	(d) A copy of any covenants or deed restrictions intended to cover all or part of the lots in the subdivision.	Y*				<p><u>Draft HOA and sample deed provided.</u></p> <p><u>Various drainage easements are necessary and are identified on the plan. To be reviewed by the Town Engineer.</u></p> <p>A 20' wide access easement to the Open Space proposed on Lot 5.</p> <p>A sign easement is proposed on Lot 1.</p> <p>The lot is subject to a 200' no cut buffer from Lot 11-A (Brigham lot).</p>
	(e) Contour lines at the interval specified by the Planning Board, showing elevations in relation to mean sea level.	Y				<p>Sheet 2 and 3 depict 1 foot contours.</p> <p>See sheet 2 with existing contours and proposed lots.</p>
	(f) The number of acres within the proposed subdivision, location of property lines, existing buildings, watercourses, vegetative cover type and other essential existing physical features. The location of any trees larger than 24 inches in diameter at breast height shall be shown on the plan.	Y*				<p>Total Area of subdivision is noted to be 26.8 acres or 1,167,484 SF. <u>Ownership extends to the bank of the Merriland River. Net area is 26.8 acres? Note 8 states 22.8 Net Acres.</u></p> <p>Trees greater than 24" in diameter are identified. <u>24" trees within the Open Space to be maintained? Tree on lot 7 and 9 to be maintained? Recommend plan note.</u></p> <p><u>Do any historical mill sites exist along the Merriland River in this location?</u></p>
	(g) Indication of the type of sewage disposal to be used in the subdivision.	Y				<p>See note 14. Lots to be served by individual on-site septic systems.</p>

Town of Wells, Maine
Preliminary Major Subdivision Plan Completeness Review
Page 4 of 7

Project Name/Map & Lot #: Hobbs Pond Woods- Tax Map 62, Lot 11-A-1

Prepared By: Planning Office

Plans Dated: 3/22/19; 4/16/19

District: R and ShO

Review Date: 4/2/19; 4/30/19

Prelim. Plan Revisions Submittal Date: 4/26/19

§ 202- 8. Preliminary Plan for Major Subdivision	Application Meet Requirements				
	Yes	No	NA	Waiver	Comments
[1] When sewage disposal is to be accomplished by connection to the public sewer, a letter from the Wells Sanitary District indicating that there is adequate capacity within the district's system to transport and treat the sewage shall be submitted.				NA	
[2] When sewage disposal is to be accomplished by subsurface sewage disposal systems, test pit analyses prepared by a licensed site evaluator shall be provided. A map showing the location of all test pits dug on the site shall be submitted.	Y*				Test pit logs provided by Mark Hampton 263/216. Plans identify test pit locations and primary and reserve septic system locations for each lot. <u>Lot 1 septic system locations would require cutting in the no cut buffer for the Brigham lot.</u>
(h) Indication of the type of water supply system(s) to be used in the subdivision. When water is to be supplied by public water supply, a letter from the Kennebunk, Kennebunkport and Wells Water District shall be submitted indicating that there is adequate supply and pressure for the subdivision.	Y*				See note 15. Proposed lots shall be served by on-site drilled wells. Dug wells are prohibited. Wells zones are depicted. <u>Wells on Lot 1 and 2 possible due to 200' no cut buffer required by Lot 11A (Brigham lot)?</u>
(i) The date the plan was prepared, North point (identified as true or magnetic), graphic map scale, and names and addresses of the record owner, subdivider and individual or company who or which prepared the plan.	Y				True North noted. Plan scale is 1" = 100 feet on sheet 1 and 1" = 40 feet on sheet 2 and 3. Record owner and applicant noted.
(j) The names and addresses of owners of record of adjacent property, including any property directly across an existing public street from the subdivision.	Y				Abutters are identified.
(k) The location of any zoning boundaries affecting the subdivision.	Y				The Rural zone and 75' Shoreland Overlay zone noted.

Town of Wells, Maine
Preliminary Major Subdivision Plan Completeness Review
Page 5 of 7

Project Name/Map & Lot #: Hobbs Pond Woods- Tax Map 62, Lot 11-A-1

Prepared By: Planning Office

Plans Dated: 3/22/19; 4/16/19

District: R and ShO

Review Date: 4/2/19; 4/30/19

Prelim. Plan Revisions Submittal Date: 4/26/19

§ 202- 8. Preliminary Plan for Major Subdivision		Application Meet Requirements				
		Yes	No	NA	Waiver	Comments
	(l) The location and size of existing and proposed sewers, water mains, culverts and drainageways on or adjacent to the property to be subdivided.	Y				See sheet 3 for proposed grading and drainage. Roadside swales, level spreader and forested buffer . Driveway culvert detail provided. Preliminary Stormwater Management Plan provided. <u>Design and analysis to be provided with the final subdivision applicaiton and to be reviewed by Town Engineer.</u>
	(m) The location, names and present widths of existing and proposed streets, highways, easements, building lines, parks and other open spaces on or adjacent to the subdivision.	Y				Meetinghouse Road is labelled on the plan sets. Existing and proposed ROW widths, adjacent buildings, easements and boundary details noted.
	(n) The width and location of any streets or public improvements shown upon the Official Map and the Comprehensive Plan, if any, within the subdivision.			NA		No such public improvements proposed.
	(o) The proposed lot lines with approximate dimensions and lot areas.	Y*				All lots proposed shall exceed the minimum of 20,000 SF per 145-49, <u>pending Planning Board determinations.</u> <u>Lot 1 buildability is in question. (The well location is very limited; septic system construction will impact the 200' no cut buffer required; this leaves a very restricted building envelope for a house to be built).</u>
	(p) All parcels of land proposed to be dedicated to public use and the conditions of such dedication.			NA		No such dedication proposed.

Town of Wells, Maine
Preliminary Major Subdivision Plan Completeness Review
Page 6 of 7

Project Name/Map & Lot #: Hobbs Pond Woods- Tax Map 62, Lot 11-A-1

Prepared By: Planning Office

Plans Dated: 3/22/19; 4/16/19

District: R and ShO

Review Date: 4/2/19; 4/30/19

Prelim. Plan Revisions Submittal Date: 4/26/19

§ 202- 8. Preliminary Plan for Major Subdivision	Application Meet Requirements				
	Yes	No	NA	Waiver	Comments
(q) The location of any open space to be preserved and an indication of its improvement and management.	Y*				Open Space is identified and noted to be 17 acres or 63% or 64% <u>See note 19. Open Space and ROW ownership and maintenance responsibilities are of the Homeowners' Association.</u>
(r) A copy of that portion of the county soil survey covering the subdivision. When the medium-intensity soil survey shows soils which are generally unsuitable for the uses proposed, the Board may require the submittal of a report by a registered soil scientist indicating the suitability of soil conditions for those uses.	Y				SCS Map provided
(s) If any portion of the subdivision is in a flood-prone area, the boundaries of any flood hazard areas and the one-hundred-year-flood elevation shall be delineated on the plan.	Y*				100 year flood zone depicted. FIRM # to be noted.
(t) A hydrogeologic assessment prepared by a certified geologist or registered professional engineer, experienced in hydrogeology, when the subdivision is not served by public sewer and:			NA		Not required as the subdivision is not located over a gravel or sand aquifer and has an average density greater than 100,000 SF per dwelling.
[1] Any part of the subdivision is located over a sand and gravel aquifer, as shown on a map entitled "Hydrogeologic Data for Significant Sand and Gravel Aquifers" by the Maine Geological Survey, 1985, Map Nos. 2 and 4; or			NA		
[2] The subdivision has an average density of less than 100,000 square feet per dwelling unit.			NA		
(u) The location of any wetlands, streams, rivers, brooks or ponds located within or adjacent (within 75 feet) to the proposed subdivision.	Y*				A stream and the Merriland River are identified. <u>Mark Hampton's wetland delineation report was not provided. Were Vernal Pools investigated and identified?</u>
(v) The location of any significant wildlife or fisheries habitat as located by the Department of Inland Fisheries and Wildlife.	Y*				An IF&W letter dated 4/30/19 was provided. <u>Further guidance recommended regarding bats and vernal pools.</u> <u>A vernal pool evaluation is pending.</u>

Town of Wells, Maine
Preliminary Major Subdivision Plan Completeness Review
Page 7 of 7

Project Name/Map & Lot #:	Hobbs Pond Woods- Tax Map 62, Lot 11-A-1	District:	R and ShO
Prepared By:	Planning Office	Review Date:	4/2/19; 4/30/19
Plans Dated:	3/22/19; 4/16/19	Prelim. Plan Revisions Submittal Date:	4/26/19

Notes:

- Fire Chief and Public Works Director to provide approval/ comments on the alternative turn-tee proposed
- Applicant proposes Fire Protection to be served by an off-site fire pond located within 1 mile of furthest driveway within the proposed development (Dry Hydrant 4,000 feet away on Sanford Road). Fire Chief must review and provide a written opinion on this fire protection method.