



Kennebunk, Kennebunkport & Wells Water District

Proudly serving since 1921

Trustees:
Thomas P. Oliver (Wells)
Robert Emmons (Kennebunk)
James E. Burrows (Kennebunkport)
Frederick A. Lynk (Ogunquit)

Stephen P. Cox, Superintendent
Scott J. Minor, Assistant Superintendent
Wayne A. Brockway, Treasurer

February 3, 2022

Brian Nielsen E.I.T.
Attar Engineering Inc.
1284 State Road
Eliot, ME 03903

Subject: 2229 Post Road Wells Map 147 Lot 13.

Dear Mr. Nielsen:

This letter is to inform you that near the above location an adequate domestic water supply is available from the District's 16-inch water main along Post Road. Water pressure in this area typically averages approximately 65 PSI. For fire suppression purposes approximately 1200 gallons per minute at 20 PSI residual pressure is available near this location. This figure is an estimate for planning purposes only. An actual field test should be performed by the owner's agent prior to designing any fire suppression system.

The owner may be assessed an appropriate share of the costs of system expansion which will include but may not be limited to a System Development Charge, based upon meter size and/or anticipated water consumption, as approved by the Maine Public Utilities Commission.

This lot is currently served by a 2" service line. If new units are added or upgraded service is needed to meet any additional demand that may result from this change of use, the owner will be allowed to request one pursuant to the District's rules and regulations in effect at that time.

Please call if you have any additional questions.

Sincerely,

Assistant Distribution Manager