



# Town of Wells, Maine

## Planning Board

**FINDINGS OF FACTS & DECISIONS**  
**Final Subdivision Application for “The Timbers”**  
**Page 1 of 19**

### Chapter 202 Subdivision of Land

PROJECT INFORMATION	
<b>General:</b>	<p><b>Project Name:</b> The Timbers Subdivision</p> <p><b># Lots Proposed:</b> 2 lots/ 10 dwelling units</p> <p><b>Applicant:</b> Patrick W. Johnson, PLS, JPS Professional Services, 7 Traditional Lane, Kennebunk, ME 04043</p> <p><b>Landowner:</b> RT Property Holdings, LLC, 1371 Meetinghouse Road, Wells, ME 04090</p> <p><b>Location:</b> Near 1663 Sanford Road, Wells, ME</p> <p><b>Existing Use:</b> Vacant Land</p> <p><b>Proposed Land Use:</b> Major Subdivision consisting of 2 lots. Lot 13-1 for a single family dwelling. Lot 13-2 for three 3-dwelling unit Multifamily Dwelling units (Multifamily Development per 145-48)</p> <p><b>Tax Parcel ID:</b> Currently Tax Map 55, Lot 13-EXE and 14-EXE to become Lot 13-1 and 13-2</p> <p><b>Zoning District:</b> Resident A District</p> <p><b>Chpt 145, Art VII Performance Standards:</b> 145-48. Multifamily Development.</p> <p><b>Design Engineer:</b> Patrick W. Johnson, PLS, JPS Professional Services, 7 Traditional Lane, Kennebunk, ME 04043</p> <p><b>Final Plan Application Submission Date:</b> October 12, 2022</p> <p><b>Plan Submission Date:</b> October 12, 2022</p>
<b>Project Description:</b>	<p>Patrick Johnson of JPS Professional Services, has submitted a Final Subdivision application on behalf of the property owner, RT Property Holdings, LLC. The subdivision is proposed on a 10.62 acre parcel of land. The subdivision to consist of 2 lots and a total of 10 dwelling units. Lot 1 to consist of one single family dwelling unit on a 42,028 SF parcel. Lot 2 to consist of three 3-unit multifamily dwelling units on a 420,448 SF parcel (Multifamily Development). The subdivision has frontage off Route 109 (Sanford Road). The dwellings are to be served by on-site septic systems and drilled wells. The subdivision is located within the Residential A District. Tax Map 55, lot 13-EXE (portion) and Lot 14-EXE. Lots to be merged and identified as Map 55, Lot 13-1 and 13-2.</p>
<b>Approval Dates:</b>	<p>Preliminary Plan Approval: 8/15/2022</p> <p>Final Plan Approval: <b><u>To be determined</u></b></p>
<b>Public Hearings:</b>	<p>Preliminary Public Hearing: 8/15/2022</p> <p>Final Public Hearing: 11/28/2022</p>



# Town of Wells, Maine

## Planning Board

### FINDINGS OF FACTS & DECISIONS

#### Final Subdivision Application for “The Timbers“

Page 2 of 19

#### PROJECT HISTORY

1. On 1/31/22 the applicant submitted a subdivision pre-application and sketch plan.
2. On 2/1/22 the Planning Office mailed abutters notice of the subdivision pre-application and of the 2/14/22 meeting.
3. On 2/8/22 the Planning Office prepared an Article V and VII review checklist. A memo summarizing the review comments was also prepared for the applicant and Planning Board.
4. On 2/14/22 the Planning Board received the subdivision pre-application and scheduled a site walk for 4/9/22.
5. On 3/21/22 the Planning Board voted to reschedule the site walk to 4/2/22.
6. On 3/29/22 the applicant submitted a Preliminary Subdivision Application and plan to the Planning Office.
7. On 4/2/22 the Planning Board conducted a site walk of the property.
8. On 4/9/22 the Planning Office prepared a site walk results memo.
9. On 4/12/22 the Planning Office mailed notice to abutters of the Preliminary Subdivision Application submission and of the 4/25/22 Planning Board meeting.
10. On 4/18/22 the Planning Office prepared updated Article V, VII review checklists, a draft completeness checklist and memo for the applicant and Planning Board.
11. On 4/25/22 the Planning Board received the Preliminary Subdivision Application and continued the workshop for 60 days.
12. On 6/17/22 the applicant submitted a revised subdivision plan.
13. On 6/20/22 the Planning Board granted a 60 day extension.
14. On 7/5/22 the applicant submitted an IF&W letter and map for the project.
15. On 7/6/22 the Planning Office prepared updated Article V, VII and completeness review checklists. A memo was prepared for the applicant and Planning Board.
16. On 7/8/22 the applicant submitted revised plans, road name request for, and test pits to the Planning Office.
17. On 7/11/22 the Planning Board conducted a workshop and appointed the Planning Office as the completeness agent so a public hearing could be set.
18. On 8/3/22 the applicant submitted a Hydrogeologic Assessment for the subdivision.
19. On 8/3/22 the Planning Office found the application complete and mailed abutters notice of the preliminary public hearing to be held on 8/15/22.
20. On 8/10/22 the Planning Office prepared updated Article V, VII and completeness review checklists. Recommended plan markups were prepared.
21. On 8/11/22 the Planning Office provided the recommended plan markups to the applicant.
22. On 8/12/22 the Planning Office prepared preliminary Findings of Fact & Decisions and a memo.
23. On 8/15/22 the Planning Board conducted a preliminary public hearing and workshop. The Board voted to grant preliminary subdivision approval and sign the Preliminary Findings of Fact & Decisions.
24. On 10/12/22 the applicant submitted the Final Subdivision Application and plans to the Planning Office.
25. On 10/27/22 the Planning Office prepared a review memo and draft final completeness review checklist for the Planning Board and applicant. Recommended plan revisions were provided to the applicant.
26. On 10/27/22 the Town Planner/ Engineer prepared a Deed Document review memo.
27. On 10/28/22 the Town Planner/Engineer prepared a Stormwater Management Design and Analysis memo and a revised review memo for the applicant and Planning Board.
28. On 10/31/22 the Planning Board received the final subdivision application and conducted a workshop.
29. On 11/4/22 the applicant submitted Condominium documents, revised sample deed and sight distance plans.
30. On 11/9/22 the applicant submitted revised plans, stormwater and supporting information for review.
31. On 11/15/22 the Planning Office mailed abutters certified notice of the final public hearing.
32. On 11/18/22 the Planning Office prepared revised final completeness and draft compliance/ Final Findings of Fact & Decisions for the applicant and Planning Board.



# Town of Wells, Maine

## Planning Board

**FINDINGS OF FACTS & DECISIONS**  
**Final Subdivision Application for “The Timbers”**  
**Page 3 of 19**

<b>§ 202-12. General Standards</b>	<b>Findings &amp; Decisions</b>
<p>In reviewing applications for a subdivision, the Board shall consider the following general standards and make findings that each has been met prior to the approval of a final plan. In all instances the burden of proof shall be upon the applicant.</p>	
<p>A. Conformance with Comprehensive Plan. All proposed subdivisions shall be in conformity with the Comprehensive Plan of the municipality and with the provisions of all pertinent state and local codes and ordinances.</p>	
<p>B. Retention of open spaces and natural or historic features. [Amended 6-11-2013]</p>	
<p>(1) In any subdivision with no more than five lots or dwelling units, no dedicated open space is required. In any subdivision with at least six lots or dwelling units and no more than 10 lots or dwelling units, there shall be a minimum of 10% or 20,000 square feet, whichever is greater, of the total property net area dedicated as open space. Off site dedication of open space land may be approved by the Planning Board if excess land is provided and the land has a greater benefit to the public than land within the development. In any subdivision with more than 10 lots or dwelling units, there shall be a minimum of 35% of the total property net area dedicated as open space.</p>	<p>This subdivision proposes no more than 10 dwelling units and is required to provide a minimum of 10% Open Space. <b><u>Plan note 18 on G1 to be revised.</u></b> This subdivision proposes approximately 43.2% open space or 4.59 acres of the 10.62 acres.</p>
<p>(2) Land reserved for open space purposes shall be of a character, configuration and location suitable for the particular use intended. A site intended to be used for active recreation purposes, such as a playground or a play field, should be relatively level and dry. Sites selected primarily for scenic or passive recreation purposes shall have such access as the Planning Board may deem suitable. The configuration of such sites shall be deemed adequate by the Planning Board with regard to scenic or historic attributes to be preserved, together with sufficient areas for trails, lookouts, etc., where necessary and appropriate.</p>	<p>See note 18 on sheet G1. The Open Space shall be retained by the RT Property Holdings, LLC, successors or assigns or a Condominium Association. <b><u>Open space shall be used for passive recreation use only.</u></b></p> <p><b><u>Planning Board to consider finding the proposed Open Space as suitable on 11/28/22.</u></b></p>
<p>(3) Reserved open space land, acceptable to the Planning Board and subdivider, may be dedicated or conveyed to the municipality, a land trust, or other recognized conservation organization. Such reservation may also be accomplished by incorporation into homeowners' association or condominium association documents or into restrictive deed covenants. (See § <b><u>145-49</u></b>, residential cluster development standards.)</p>	<p>No such reservation proposed.</p>
<p>(4) The Planning Board may require that the development plans include a landscape plan that will show the preservation of any existing trees larger than 24 inches in diameter at breast height, the replacement of trees and vegetation, graded contours, streams and the preservation of scenic, historic or environmentally significant areas. Cutting of trees on the northerly borders of lots should be avoided as far as possible, to retain a natural wind buffer.</p>	<p>Trees greater than 24" in diameter are noted on sheet S2. Sheet E1 identifies the 24" diameter trees that are proposed to be removed.</p>



# Town of Wells, Maine

## Planning Board

**FINDINGS OF FACTS & DECISIONS**  
**Final Subdivision Application for “The Timbers”**  
**Page 4 of 19**

<b>§ 202-12. General Standards</b>		<b>Findings &amp; Decisions</b>
C.	Blocks. Where street lengths exceed 1,000 feet between intersections with other streets, the Board may require an utility/pedestrian easement, at least 20 feet in width, to provide for underground utility crossings and/or a pedestrian pathway of at least five feet in width. Maintenance obligations of the easement shall be included in the written description of the easement.	
D.	Lots.	
	(1) All lots shall meet the minimum requirements of Chapter 145, Land Use, for the zoning district in which they are located. The lot configuration should be designed to maximize the use of solar energy on building sites with suitable orientation.	<p>§145-21. Residential A District requirements apply to the 10 dwelling units proposed on lot 1 and 2. Proposed lot 1 to contain a single family dwelling. Proposed lot 2 to consider of a total of 9 dwelling units or three 3-unit Multifamily Dwelling units which are also considered a Multifamily Developer per 145-48. <b><u>Density table is missing from S3.</u></b></p> <p>See note 20 on G1. The driveway and house footprints shown are typical only and may vary at the time of building permit provided minimum building separation of 30 feet is maintained.</p> <p>No portion of the subdivision is located within the Shoreland Overlay zone.</p>
	(2) Lot configuration and area shall be designed to provide for adequate off-street parking and service facilities based upon the type of development contemplated. Wherever possible, parking areas shall be laid out to coincide with building locations to maximize solar energy gain.	<p>Lot 1 driveway shall be designed to comply with Chapter 201 and must provide an on-site turnaround so vehicles are not backing out on to roadways. <b><u>Recommend plan note 28 on G1.</u></b></p> <p>See plan note 7. Driveways that exceed 150 feet in length require an on-site turnaround sufficient to provide access to emergency vehicles.</p> <p>Note 7 states parking along Foliage Way is prohibited. <b><u>Plan to note parking along Route 109 is prohibited as well.</u></b></p>
	(3) Lots with multiple frontages shall be avoided wherever possible. When lots do have frontage on two or more roads, the plan and deed restrictions shall indicate that vehicular access shall be located only on the less traveled way.	<b><u>Plan note 28 recommended. Lot 1 shall be deed restricted to have vehicular access off of Foliage Way only.</u></b> No driveways are permitted onto Route 109.
	(4) Wherever possible, side lot lines shall be perpendicular to the street.	
	(5) The subdivision of tracts into parcels with more than twice the required minimum lot size shall be laid out in such a manner as to preclude future resubdivision.	See note 10 no G1.
	(6) Where public utilities could be extended to the subdivision in the foreseeable future, the subdivision shall be designed to accommodate the extensions of utilities.	Extensions of such utilities in this area are not planned for the foreseeable future. Lots shall be served by private individual septic systems and private individual drilled wells. See notes 9 and 16 on sheet G1.



# Town of Wells, Maine

## Planning Board

**FINDINGS OF FACTS & DECISIONS**  
**Final Subdivision Application for “The Timbers”**  
**Page 5 of 19**

<b>§ 202-12. General Standards</b>	<b>Findings &amp; Decisions</b>
(7) If a lot on one side of a river, tidal water, road or other similar barrier fails to meet the minimum requirements for lot size, it may not be combined with a lot on the other side of the river, tidal water or road to meet the minimum lot size.	
(8) Odd-shaped lots in which narrow strips are joined to other parcels in order to meet minimum lot size requirements are prohibited. The ratio of lot length to width shall not be more than three to one.	No such lots proposed.
(9) Lots shall be numbered in accordance with Chapter 201, Article I, Street Naming and Numbering, of the Wells Municipal Code.	Lot 1 shall be identified as Map 55, Lot 13-1 and lot 2 shall be identified as Map 55, Lot 13-2.
(10) Where the Board finds that safety considerations so require, driveways of adjoining lots shall be combined or joined so as to minimize the number of driveway entrances and maximize the distance between entrance points.	<b><u>On 11/28/22 the Planning Board shall consider determining shared driveways are not required.</u></b>
(11) Proposed lots shall not be permitted to have driveway entrances onto existing arterial or collector streets unless the Planning Board determines that no reasonable alternate exists.	<b><u>See recommended plan note 28. Driveways are prohibited onto Route 109.</u></b>
<b>E. Utilities.</b>	
(1) Utilities shall be installed underground except as otherwise approved by the Board.	Note 24 on sheet G1 requires utilities to be installed prior to final gravel base.
(2) Underground utilities shall be installed prior to the installation of the final gravel base of the road.	Note 24 on sheet G1 requires utilities to be installed prior to final gravel base.
(3) The size, type and location of streetlights, electric and gas lines, telephone and other utilities shall be shown on the plan and approved by the Board.	See sheet U1. A new utility pole is proposed along Route 109 and underground utilities to be installed from this new pole.  Changes to transformer locations to do trigger a subdivision amendment. See plan note 24.  Streetlights may be installed but are not required.
<b>F. Required improvements. The following improvements are required for all subdivisions unless waived by the Board in accordance with provisions of these regulations.</b>	
(1) Monuments.	Sheet S3 identifies all Monumentation proposed and monuments found.
(a) Stone or concrete monuments shall be set at all street intersections and points of curvature, but no further than 750 feet apart along street lines without curves or intersections.	
(b) Stone or concrete monuments shall be set at all corners and angle points of the subdivision boundaries where the interior angle of the subdivision boundaries is 135° or less. New monumentation shall not be required at corner or angle points where there is existing monumentation that complies with this section.	



# Town of Wells, Maine Planning Board

**FINDINGS OF FACTS & DECISIONS**  
**Final Subdivision Application for “The Timbers”**  
**Page 6 of 19**

§ 202-12. General Standards	Findings & Decisions
(c) Stone monuments shall be a minimum of four inches square at the top and four feet in length and set in the ground at final grade level. After they are set, drill holes one-half-inch deep shall locate the point or points described above.	
(d) Concrete monuments shall be portland cement reinforced with half-inch reinforcement bar. Concrete monuments shall be either four inches square or four inches in diameter and four feet in length and set in the ground at final grade with their top flush to four inches above the final grade.	
(e) All other subdivision boundary corners and angle points, as well as all lot boundary corners and angle points, shall be marked by suitable monumentation.	<b><u>On 11/28/22 the Planning Board to consider determining the Monumentation shown to be acceptable.</u></b>
(2) Water supply.	
(a) When a subdivision is to be served by the Kennebunk, Kennebunkport and Wells Water District, the complete supply system, including fire hydrants, shall be installed at the expense of the subdivider.	Subdivision not served by the KKW Water District.
[1] The subdivider shall provide a written statement from the Water District that adequate water for both domestic and fire-fighting purposes can be provided without placing an undue burden on the source, treatment facilities or distribution system involved. The subdivider shall be responsible for paying the costs of system improvements necessary to serve the subdivision.	
[2] The size and location of mains, gate valves, hydrants and service connections shall be reviewed and approved in writing by the Water District and the Fire Chief.	
(b) When the location of a subdivision does not allow for a financially reasonable connection to the Kennebunk, Kennebunkport and Wells Water District, the Planning Board may allow the use of individual wells or a private community water system.	The subdivision proposes an individual well for Lot 13-1 and 3 wells on Lot 13-2. The 3 wells on lot 13-2 shall provide water service to the three 3-unit buildings proposed.
[1] Dug wells shall be permitted only if it is demonstrated to be not economically feasible to develop other groundwater sources and shall be constructed so as to prevent infiltration of surface water into the well. Unless otherwise permitted by the Board, the subdivider shall prohibit dug wells by deed restrictions and a note on the plan.	See note 9 on sheet G1.
[2] If a central water supply system is provided by the subdivider, the location and protection of the source and the design, construction and operation of the system shall conform to the standards of the Maine Rules Relating to Drinking Water (10-144 A.C.M.R. 231).	Not applicable. Central water supply system not proposed.
[3] Fire protection. <b>[Amended 3-11-2002]</b>	




# Town of Wells, Maine

## Planning Board

**FINDINGS OF FACTS & DECISIONS**  
**Final Subdivision Application for “The Timbers”**  
**Page 7 of 19**

<b>§ 202-12. General Standards</b>	<b>Findings &amp; Decisions</b>
<p>[a] The subdivider shall construct dry hydrants connected to ponds or water storage tanks, provide fire hydrants connected to a public water source or implement an alternative program approved by the Fire Chief to provide for adequate water for fire-fighting purposes within the subdivision. An easement shall be granted to the municipality providing access to the hydrants or other improvements where necessary. If a subdivision has fewer than 10 lots or dwelling units or any combination of lots and dwelling units, the Board, may waive the requirement for an adequate on-site water supply only upon submittal of evidence that:</p>	<p>The subdivision proposes to construct all dwellings with individual sprinkler systems for fire protection. See note 11 on sheet G1.</p> <p><b><u>A letter from the Wells Fire Chief is pending.</u></b></p>
<p>[i] There is a fire pond, fire hydrant connected to public water, or another water source within one mile of the subdivision that the subdivider has obtained the legal right to use for fire protection purposes; and</p>	<p>Not applicable.</p>
<p>[ii] The Fire Chief has determined that the proposed water source has sufficient capacity to serve the needs of the subdivision and any other subdivisions currently using or relying on the water source for fire protection.</p>	<p><b><u>A letter from the Wells Fire Chief is pending.</u></b></p>
<p>[b] For purposes of this section, the 1-mile distance is measured from the pond, water source or fire hydrant to the driveway of the subdivision residence located farthest from the water supply along routes that fire trucks can safely travel year round.</p>	<p>Not applicable.</p>
<p>[4] The results of the water quality test submitted shall indicate that the groundwater meets the primary drinking water standards of the Maine Rules Relating to Drinking Water for those categories tested. If the Board has reason to believe, due to previous uses of the property or due to previous or existing uses of neighboring property, that the existing water quality may be threatened by contaminants not tested for in the primary inorganic water analysis, it may require the water to be tested for those contaminants.</p>	<p>This is a condition of approval to be provided prior to the issuance of a building permit.</p> <p><b><u>Water quality noted as concern. When will the well on lot 1 be drilled?</u></b></p> <p><b><u>Evidence that adequate groundwater quantity is required per 202-9B5(b)[2]</u></b></p>
<p>( c ) Prior to the issuance of a building permit for the construction of any principal structure in a subdivision, the applicant shall present evidence of suitable water supply to the Code Enforcement Officer. This evidence shall consist of:</p>	<p>This is a condition of approval.</p>
<p>[1] A letter from the Kennebunk, Kennebunkport and Wells Water District indicating availability of service; or</p>	<p>Not applicable.</p>
<p>[2] The results of a primary inorganic water analysis performed upon the well to serve the structure indicating the groundwater meets the primary drinking water standards of the Maine Rules Relating to Drinking Water for those categories tested.</p>	<p>This is a condition of approval.</p>



# Town of Wells, Maine

## Planning Board

**FINDINGS OF FACTS & DECISIONS**  
**Final Subdivision Application for “The Timbers”**  
**Page 8 of 19**

§ 202-12. General Standards	Findings & Decisions
(3) Sewage disposal.	
(a) Public system.	Subdivision not served by the Wells Sanitary District.
[1] A sanitary sewer system shall be installed at the expense of the subdivider when there is a public sanitary sewer line located within 1,000 feet of the proposed subdivision at its nearest point. The Wells Sanitary District shall certify that providing service to the proposed subdivision is within the capacity of the district's collection and treatment system.	
[2] The district shall review and approve in writing the construction drawings for the sewage system.	
(b) Private systems.	The subdivision shall be served by on-site septic systems. See sheet E1 and U1.  Minor deviations in subsurface system placement shall be approved by the Town Code Officer ( $\pm$ 10 feet). See note 16 on sheet G1.
[1] The developer shall submit evidence of soil suitability for subsurface sewage disposal prepared by a Maine licensed site evaluator in full compliance with the requirements of the State of Maine Subsurface Wastewater Disposal Rules. In addition, on lots in which the limiting factor has been identified as being within 24 inches of the surface, a second site with suitable soils shall be shown as a reserve area for future replacement of the disposal area. The reserve areas shall be shown on the plan and restricted so as not to be built upon.	The subdivision shall be served by on-site septic systems. See sheet E1 and U1.  Test pit logs prepared by James Logan, LSE/ CSS# 237/213 dated 2/9/22.  Primary systems proposed all have suitable test pit limiting factors greater than 24 inches.
[2] In no instances shall a disposal area be permitted on soils or on a lot which requires a new system variance from the subsurface wastewater disposal rules.	
(4) Stormwater management. <b>[Amended 4-27-2007]</b>	Pre and Post Drainage plans provided on 10/14/22 prepared and stamped by J. Keith Maxwell, PE #16315 <b><u>of USA Surveying Engineering.</u></b>  <b><u>A statement or report and additional information from the design engineer is required. See Town Engineer memo dated 10/28/22.</u></b>  <b><u>The current submittal does not comply with the MDEP Design Manual. Additional information provided, to be reviewed.</u></b>





# Town of Wells, Maine

## Planning Board

**FINDINGS OF FACTS & DECISIONS**  
**Final Subdivision Application for “The Timbers”**  
**Page 9 of 19**

<b>§ 202-12. General Standards</b>	<b>Findings &amp; Decisions</b>
(a) Where a subdivision is traversed by a stream, river or surface water drainageway, or where the Board feels that surface water runoff to be created by the subdivision should be controlled, there shall be provided easements or drainage rights-of-way with swales, culverts, catch basins or other means of channeling surface water within the subdivision and over other properties. This stormwater management system shall be designed by a registered professional engineer.	
(b) Drainage easements for existing watercourses or proposed drainageways shall be provided and indicated on the plan.	
(c) The developer shall provide a statement from the designing engineer that the proposed subdivision will not create erosion, drainage or runoff problems either in the subdivision or in other properties. The engineer shall certify that peak runoff from the subdivision onto other properties shall not be increased either in volume or duration from the peak runoff characteristics existing prior to development.	
(d) A stormwater management plan, meeting the standards of Chapter 201, Streets and Sidewalks, Articles II and III, Wells Municipal Code, shall be submitted.	
(e) For subdivisions that require MDEP review under 38 M.R.S.A. § 481 et seq. (Site Location of Development), a stormwater management plan shall be submitted which complies with the Site Location of Development permit and the requirements of MDEP Chapter 500 Stormwater Regulations.	
(f) For subdivisions that do not require a Site Location of Development permit, but that require a MDEP permit pursuant to 38 M.R.S.A. § 420-D, a stormwater management plan shall be submitted which complies with the requirements of MDEP Chapter 500 Stormwater Regulations.	
(g) For subdivisions outside of the watershed of a great pond that neither require a Site Location of Development permit, nor a MDEP permit pursuant to 38 M.R.S.A. § 420-D, a stormwater management plan shall be submitted which incorporates the low-impact development techniques set forth in Volume I, Chapter 3 of the Maine Stormwater Best Management Practices Manual, 2006 (LID Techniques) on each individual lot approved by the Planning Board when such LID Techniques are adopted by MDEP. At such time that the MDEP adopts the LID Techniques, the Planning Board shall adopt them for use in approving subdivisions for the Town of Wells.	



# Town of Wells, Maine

## Planning Board

**FINDINGS OF FACTS & DECISIONS**  
**Final Subdivision Application for “The Timbers”**  
**Page 10 of 19**

<b>§ 202-12. General Standards</b>		<b>Findings &amp; Decisions</b>
	<p>(h) For subdivisions located within the watershed of a great pond containing: 1. five or more lots or dwelling units created within any five-year period; or 2. any combination of 800 linear feet of new or upgraded driveways and/or streets, a stormwater management plan shall be submitted that meets the phosphorus allocation across the entire subdivision in accordance with the methodology described in the MDEP Phosphorus Design Manual, Volume II of the Maine Stormwater Best Management Practices Manual, 2006.</p>	
	<p>(i) The Planning Board may require a hydrologic analysis for any site in areas with a history of flooding or in areas with a potential for future flooding, associated with cumulative impacts of development. This hydrologic analysis would be in the form of a “Downstream Analysis” under conditions of the ten-year, twenty-four-hour storm, the twenty-five-year, twenty-four-hour storm, and the one-hundred-year, twenty-four-hour storm, as described below:</p>	
	<p>[1] Downstream Analysis Methodology: The criteria used for the downstream analysis is referred to as the “10% rule.” Under the 10% rule, a hydrologic and hydraulic analysis for the ten-year, twenty-four-hour storm, the twenty-five-year, twenty-four-hour storm, and the one-hundred-year, twenty-four-hour storm is extended downstream to the point where the site represents 10% of the total drainage area. For example, a ten-acre site would be analyzed to the point downstream with a drainage area of 100 acres. This analysis should compute flow rates and velocities downstream to the location of the 10% rule for present conditions and proposed conditions. If the flow rates and velocities increase by more than 5% and/or if any existing downstream structures are impacted, the designer should redesign and incorporate detention facilities.</p>	
G.	Streets.	
	<p>(1) All streets in a subdivision shall meet Chapter 201, Streets and Sidewalks, Articles II and III, Wells Municipal Code.</p>	<p>The proposed streets must comply with the requirements of Chapter 201. Foliage Way is a proposed private road that will not be considered for acceptance by the Town of Wells. See note 20, Sheet G1.</p>



# Town of Wells, Maine

## Planning Board

### FINDINGS OF FACTS & DECISIONS

#### Final Subdivision Application for "The Timbers"

Page 11 of 19

§ 202-12. General Standards		Findings & Decisions
(2)	Any subdivision expected to generate average daily traffic of 200 trips per day or more shall have at least two street connections with existing public streets, streets shown on an Official Map or streets on an approved subdivision plan for which performance guaranties have been filed and accepted. Any street with an average daily traffic of 200 trips per day or more shall have at least two street connections leading to existing public streets, streets shown on an Official Map or streets on an approved subdivision plan for which performance guaranties have been filed and accepted. Said two street connections' center lines shall be no closer than 400 linear feet apart. Traffic generation rates shall be based on the Traffic Generation Manual, 1988 Edition, Institute of Transportation Engineers. Some typical traffic generation rates are:	The subdivision is not expected to generate a daily traffic of 200 trips per day or more. Traffic generation is calculated to be 100 trips per day.
	(a) Single-family house: 10.0 trips per day per unit.	10 x 10.0 = 100.00 trips per day for the subdivision
	(b) Residential condominium: 5.9 trips per day per unit.	
	(c) Motel: 10.2 trips per day per room.	
	(d) Industrial: 7.0 trips per day per 1,000 square feet of floor space.	
(3)	In any subdivisions located in the Residential A Zoning District or east of U.S. Route 1 provisions shall be made for the interconnection of proposed streets with other subdivisions or adjacent properties if it is determined to be practical and desirable by the Planning Board.	<b><u>On 11/28/22 the Planning Board to consider if the subdivision shall include provisions to interconnect with other streets or subdivisions adjacent to this subdivision.</u></b> Such interconnections are not possible.
H.	Land features.	
(1)	Topsoil shall be considered part of the subdivision and shall not be removed from the site except for surplus topsoil from roads, parking areas and building excavations. Topsoil shall not be removed from the site until completion of construction and inspection by the Town to assure four inches of topsoil has been spread over all areas to be grassed.	This is a condition of approval.
(2)	Except for normal thinning, landscaping and cutting trees to provide access to direct sunlight, existing vegetation shall be left intact to prevent soil erosion. The Board shall require a developer to take the following measures to correct and prevent soil erosion in the proposed subdivision: <b>[Amended 4-27-2007]</b>	This is a condition of approval.
	(a) The proposed subdivision shall prevent soil erosion and sedimentation from entering waterbodies, wetlands, and adjacent properties.	
	(b) The procedures outlined in the erosion and sedimentation control plan shall be implemented during the site preparation, construction, and clean-up stages.	
	(c) Cutting or removal of vegetation along waterbodies shall not increase water temperature or result in shoreline erosion or sedimentation.	
	(d) Topsoil shall be considered part of the subdivision and shall not be removed from the site except for surplus topsoil from roads, parking areas, and building excavations.	



# Town of Wells, Maine

## Planning Board

**FINDINGS OF FACTS & DECISIONS**  
**Final Subdivision Application for “The Timbers”**  
**Page 12 of 19**

<b>§ 202-12. General Standards</b>	<b>Findings &amp; Decisions</b>
(3) To prevent soil erosion of shoreline areas the cutting or removal of vegetation shall only be permitted as regulated in § 145-33 of Chapter 145, Land Use, of the Wells Municipal Code.	This is a condition of approval.
(4) Dedication and maintenance of common open space and services.	<b><u>Condominium Association documents are being reviewed by the Town Engineer/ Planner and Town Attorney for compliance with these standards.</u></b>
(a) All common land shall be owned jointly or in common by the owners of the dwelling units by means of a homeowners' association, by an association which has as its principal purpose the conservation or preservation of land in essentially its natural condition or by the municipality.	See note 19 and 20 on sheet G1.
(b) Further subdivision of the common land or its use for other than noncommercial recreation or conservation purposes, except for easements for underground utilities, shall be prohibited. Structures and buildings accessory to noncommercial recreational or conservation uses may be erected on the common land.	See note 19 and 20 on sheet G1.
(c) The common open space shall be shown on the final plan with appropriate notation on the plan to indicate that:	See note 19 and 20 on sheet G1.
[1] It shall not be used for future building lots; and	
[2] A part or all of the common open space may be dedicated for acceptance by the municipality.	
(d) If any or all of the common open space and services are to be reserved for use by the residents, the bylaws of the proposed homeowners' association shall specify maintenance responsibilities and shall be submitted to the Board prior to final plan approval.	See note 19 and 20 on sheet G1
(e) Covenants for mandatory membership in the homeowners' association setting forth the owners' rights, interests and privileges in the association and the common property shall be reviewed by the Board and included in the deed for each lot or dwelling.	Notes 19 and 20 and Condominium document addresses maintenance responsibilities.
(f) The homeowners' association shall have the responsibility of maintaining the common property.	Notes 19 and 20 and Condominium document addresses maintenance responsibilities.
(g) The association shall levy annual charges against all owners of dwelling units to defray the expenses connected with the maintenance of common property and tax assessments.	Notes 19 and 20 and Condominium document addresses maintenance responsibilities.
(h) The developer or subdivider shall maintain control of the common property and be responsible for its maintenance until development sufficient to support the association has taken place.	Notes 19 and 20 and Condominium document addresses maintenance responsibilities.
(5) Construction in flood hazard areas. When any part of a subdivision is located in a special flood hazard area as identified by the Federal Emergency Management Agency, the plan shall conform with Chapter 115, Floodplain Management, of the Wells Municipal Code.	No flood zone is present for the parcel per FEMA Map. See note 13 on sheet G1.
(6) Impact on groundwater.	



# Town of Wells, Maine

## Planning Board

**FINDINGS OF FACTS & DECISIONS**  
**Final Subdivision Application for “The Timbers”**  
**Page 13 of 19**

<b>§ 202-12. General Standards</b>	<b>Findings &amp; Decisions</b>
(a) When a hydrogeologic assessment is submitted, the assessment shall contain at least the following information:	A hydrogeologic assessment dated 7/26/22 was provided by Mark Cenci Geologic Inc. <b><u>Town Engineer to review the assessment as part of the final subdivision application review.</u></b>  The subdivision is not served by public sewer and has an average density of less than 100.000 SF per dwelling.
[1] A map showing the basic soils types.	
[2] The depth of the water table at representative points throughout the subdivision.	
[3] Drainage conditions throughout the subdivision.	
[4] Data on the existing groundwater quality, either from test wells in the subdivision or from existing wells on neighboring properties.	
[5] An analysis and evaluation of the effect of the subdivision on groundwater resources. In the case of residential developments, the evaluation shall, at a minimum, include a projection of post-development nitrate-nitrogen concentrations at any wells within the subdivision, at the subdivision boundaries and at a distance of 1,000 feet from potential contamination sources, whichever is a shorter distance. For subdivisions within the watershed of a pond, projections of the development's impact on groundwater phosphate concentrations shall also be provided.	
[6] A map showing the location of any subsurface wastewater disposal systems and drinking water wells within the subdivision and within 200 feet of the subdivision boundaries.	
(b) Projections of groundwater quality shall be made at any wells within the subdivision and at the subdivision boundaries or at a distance of 500 feet from potential contamination sources, whichever is a shorter distance.	
(c) Projections of groundwater quality shall be based on the assumption of drought conditions (assuming 60% of annual average precipitation).	
(d) No subdivision shall increase any contaminant concentration in the groundwater to more than 1/2 of the primary drinking water standards. No subdivision shall increase any contaminant concentration in the groundwater to more than the secondary drinking water standards.	
(e) If groundwater contains contaminants in excess of the primary standards and the subdivision is to be served by on-site groundwater supplies, the applicant shall demonstrate how water quality will be improved or treated.	
(f) If groundwater contains contaminants in excess of the secondary standards, the subdivision shall not cause the concentration of the parameters in question to exceed 150% of the ambient concentration.	



# Town of Wells, Maine

## Planning Board

**FINDINGS OF FACTS & DECISIONS**  
**Final Subdivision Application for “The Timbers”**  
**Page 14 of 19**

<b>§ 202-12. General Standards</b>		<b>Findings &amp; Decisions</b>
	(g) Subsurface wastewater disposal systems and drinking water wells shall be constructed as shown on the map submitted with the assessment. If construction standards for drinking water wells are recommended in the assessment, those standards shall be included as a note on the final plan and as restrictions in the deeds to the affected lots.	
<b>§ 202-13. Performance Guaranties. [Amended 4-12-1999]</b>		<b>Findings &amp; Decisions</b>
A.	Types of guaranties.	
(1)	With submittal of the application for final plan approval, the applicant shall provide any one or a combination of the following performance guaranties for an amount adequate to cover the total site preparation and construction costs of all required improvements, taking into account the time span of the construction schedule and the inflation rate for construction costs:	<b><u>To be reviewed.</u></b>
	(a) Either a certified check payable to the municipality or a savings account or certificate of deposit naming the municipality as owner for the establishment of an escrow account.	To be determined at the pre-construction meeting.
	(b) A performance bond payable to the municipality issued by a surety company approved by the municipal officers or Town Manager.	To be determined at the pre-construction meeting.
	(c) An irrevocable letter of credit (See Appendix B for a sample. Note: Appendix B, originally attached to the Subdivision Regulations, has not been reproduced in the Code. Consult the original Town records in the office of the Clerk. ) from a financial institution establishing funding for the construction of the subdivision from which the municipality may draw if construction is inadequate, approved by the municipal officers or Town Manager.	To be determined at the pre-construction meeting.
	(d) An offer of conditional approval prohibiting the sale of any units or lots until all required improvements serving those units or lots have been constructed to the satisfaction of the Town and in compliance with all ordinances, plans and specifications.	<b><u>The sale of lots or units is prohibited until the pre-construction meeting is held and determinations are mutually made by the developer and Town regarding performance guarantees required. To be noted.</u></b>
(2)	The conditions and amount of the performance guaranty shall be determined by the Board with the advice of the Town Planner, Road Commissioner, municipal officers and/or Town Attorney. If an offer of conditional approval is made by the applicant, pursuant to Subsection A(1)(d), the applicant shall be required, in addition, to present a cash escrow, performance bond or irrevocable letter of credit, as described in Subsections A(1)(a) through (c) above, to cover the cost of restoring the site to a stable condition, should the applicant create erosion or sedimentation problems for an unreasonable duration during site preparation or during the construction of roads and/or utilities or other required improvements.	To be determined at the pre-construction meeting.




# Town of Wells, Maine

## Planning Board

**FINDINGS OF FACTS & DECISIONS**  
**Final Subdivision Application for “The Timbers”**  
**Page 15 of 19**

<b>§ 202-12. General Standards</b>		<b>Findings &amp; Decisions</b>
B.	<p><b>Contents of guaranty.</b> The performance guaranty shall contain a construction schedule, cost estimates for each major phase of construction, taking into account inflation, provisions for inspections of each phase of construction, provisions for the release of part or all of the performance guaranty to the developer and a date after which the applicant will be in default, and the municipality shall have access to the funds to finish construction. The Board may require the services of a third party inspector, to be paid for at the expense of the applicant upon recommendation of the Town Manager.</p>	To be determined at the pre-construction meeting.
C.	<p><b>Escrow account.</b> If the applicant chooses to establish an escrow account, a cash contribution to the account shall be made by either a certified check made out to the municipality, the direct deposit into a savings account or the purchase of a certificate of deposit. For any account opened by the applicant, the municipality shall be named as owner or co-owner, and the consent of the municipality shall be required for a withdrawal. Any interest earned on the escrow account shall be returned to the applicant unless the municipality has found it necessary to draw on the account, in which case the interest earned shall be proportionately divided between the amount returned to the applicant and the amount withdrawn to complete the required improvements. The Town Attorney and Town Treasurer shall review and have final authorization on the establishment of escrow accounts.</p>	To be determined at the pre-construction meeting.
D.	<p><b>Performance bond.</b> If the applicant chooses to submit a performance bond, the performance bond shall detail any special conditions, the method for release of the bond or portions of the bond to the applicant and the procedures for collection by the municipality. The bond documents shall specifically reference the subdivision for which approval is sought.</p>	To be determined at the pre-construction meeting.
E.	<p><b>Letter of credit.</b> If the applicant chooses to submit an irrevocable letter of credit from a bank or other lending institution, at a minimum the letter shall indicate that funds have been set aside for the construction of the subdivision and may not be used for any other project or loan. The Town Manager or Town Treasurer shall certify the bank or institution as acceptable to the Town. The Town Attorney shall review and, if found acceptable, approve the wording of all letters of credit.</p>	To be determined at the pre-construction meeting.
F.	<p><b>Standard condition of approval.</b> As a standard condition of approval for all applications for which a performance guaranty is required pursuant to Subsection <b>K</b>, the Board shall require the applicant to enter into a binding agreement with the municipality regarding the development of the required improvements and the sale of lots or units in the subdivision until such time as one or more of the allowable performance guaranties have been accepted by the municipality.</p>	To be determined at the pre-construction meeting.
	<p>(1) The agreement shall prohibit the sale or occupancy of any lot or unit in the subdivision for which the improvements to be covered by the guaranty are required for access to or intended use of the lot until either:</p>	To be determined at the pre-construction meeting.
	<p>(a) It is certified by the Board, or its agent, that all of the required improvements have been installed in accordance with these regulations and the regulations of the appropriate utilities; or</p>	



# Town of Wells, Maine Planning Board

**FINDINGS OF FACTS & DECISIONS**  
**Final Subdivision Application for “The Timbers”**  
**Page 16 of 19**

<b>§ 202-12. General Standards</b>		<b>Findings &amp; Decisions</b>
	(b) A performance guaranty, acceptable to the municipality, is submitted in an amount necessary to cover the completion of the required improvements at an amount adjusted for inflation and prorated for the portions of the required improvements already installed.	
	(2) Notice of the agreement and any conditions shall be on the final plan that is recorded at the Registry of Deeds. Release from the agreement shall follow the procedures for release of the performance guaranties contained in Subsection H.	
G.	<b>Phasing of development.</b> The Board may approve plans to develop a major subdivision in separate and distinct phases. This may be accomplished by limiting final approval to those lots abutting that section of the proposed subdivision street which is covered by a performance guaranty. When development is phased, road construction shall commence from an existing public way. The subdivision shall be divided in such a manner that each phase, when aggregated with the previous phase(s), shall meet the standards of these regulations. Final approval of lots in subsequent phases shall be given only upon satisfactory completion of all requirements pertaining to previous phases.	<b><u>Phasing of the subdivision is not proposed. Applicant to confirm.</u></b>
H.	<b>Release of guaranty.</b> Prior to the release of any part of the performance guaranty, the Board shall determine to its satisfaction, in part upon the report of the Town Manager and whatever other agencies and departments may be involved, that the proposed improvements meet or exceed the design and construction requirements for that portion of the improvements for which the release is requested.	
I.	<b>Default.</b> If upon inspection the third party inspector, Municipal Engineer or other qualified individual retained by the municipality finds that any of the required improvements have not been constructed in accordance with the plans and specifications filed as part of the application, he or she shall so report in writing to the Code Enforcement Officer, the municipal officers, the Board and the applicant or builder. The municipal officers shall take any steps necessary to preserve the municipality's rights.	
J.	<b>Private streets.</b> Where the subdivision streets are to remain private streets, the following words shall appear on the recorded plan: "All streets in this subdivision shall remain private roads to be maintained to Town standards by the developer or the lot owners and shall not be accepted or maintained by the Town."	See note 20 on sheet G1. Foligage Way shall not be considered by the Town of Wells for acceptance as a Town Road/ Street.
K.	<b>Improvements guaranteed.</b> Performance guaranties shall be tendered for all improvements required to meet the standards of these regulations and for the construction of the public or private streets, stormwater management facilities, public or private sewage collection or disposal facilities and water systems that are shared by multiple dwelling units and erosion and sedimentation control measures, as well as any other improvements required by the Board.	<b><u>Established of the type, form and conditions of the Performance Guarantee is required at the pre-construction meeting.</u></b>





# Town of Wells, Maine

## Planning Board

**FINDINGS OF FACTS & DECISIONS**  
**Final Subdivision Application for “The Timbers”**  
**Page 17 of 19**

<b>§ 202-2. Purpose, criteria for approval.</b>		<b>Findings &amp; Decisions</b>
<p>The purposes of these regulations are to assure the comfort, convenience, safety, health and welfare of the people of the Town of Wells, to protect the environment and to promote the development of an economically sound and stable community. To this end, in approving subdivisions within the Town of Wells, Maine, the Planning Board shall consider the following criteria and, before granting approval, shall make findings of fact that the provisions of these regulations have been met and that the proposed subdivision will meet the guidelines of 30-A M.R.S.A. § 4404.</p>		
A.	The subdivision:	<b>The Planning Board finds that these standards shall be met.</b>
(1)	Will not result in undue water or air pollution. In making this determination, the Board shall at least consider the elevation of the land above sea level and its relation to the floodplains; the nature of soils and subsoils and their ability to adequately support waste disposal; and the slope of the land and its effect on effluents;	
(2)	Has sufficient water available for the reasonably foreseeable needs of the subdivision;	
(3)	Will not cause an unreasonable burden on an existing water supply, if one is to be utilized;	
(4)	Will not cause unreasonable soil erosion or reduction in the capacity of the land to hold water so that a dangerous or unhealthy condition may result;	
(5)	Will not cause unreasonable highway or public road congestion or unsafe conditions with respect to use of the highways or public roads existing or proposed;	
(6)	Will provide for adequate solid and sewage waste disposal;	
(7)	Will not cause an unreasonable burden on the ability of the Town to dispose of solid waste and sewage if municipal services are to be utilized;	
(8)	Will not have an undue adverse effect on the scenic or natural beauty of the area, aesthetics, historic sites or rare and irreplaceable natural areas or any public rights for physical or visual access to the shoreline;	
(9)	Is in conformance with this chapter, the Comprehensive Plan for the Town and Chapter 145, Land Use, of the Wells Municipal Code, as amended;	
(10)	Whenever situated, in whole or in part, within 250 feet of any pond, lake, river or tidal waters, will not adversely affect the quality of the body of water or unreasonably affect the shoreline of that body of water; and	
(11)	Will not, alone or in conjunction with existing activities, adversely affect the quality or quantity of groundwater;	
B.	The subdivider has adequate financial and technical capacity to meet the above-stated standards;	<b>The Planning Board finds that these standards shall be met.</b>



# Town of Wells, Maine

## Planning Board

### FINDINGS OF FACTS & DECISIONS

#### Final Subdivision Application for “The Timbers”

Page 18 of 19

C.	If any part of a subdivision is located in a flood-prone area, as indicated on the Federal Emergency Management Agency's Flood Boundary and Floodway Maps and Flood Insurance Maps, the subdivider shall determine the one-hundred-year flood elevation and flood hazard boundaries within the subdivision. The proposed subdivision plan shall include a condition requiring that principal structures will be constructed with their lowest floor, including the basement, at least one foot above the one-hundred-year flood elevation; and	<b>Not applicable.</b>
D.	The long-term cumulative effects of the proposed subdivision will not unreasonably increase a great pond's phosphorous concentration during the construction phase and life of the proposed subdivision.	<b>Not applicable.</b>

#### **STANDARD CONDITIONS OF APPROVAL**

1. Any subdivision not recorded in the Registry of Deeds within 90 days of the date upon which the plan is approved and signed by the Board shall become null and void, unless an extension is granted by the Board in writing before the expiration of the ninety-day period. (§202-9C(2))
2. Prior to the issuance of a building permit for a principal structure in the subdivision, the applicant shall present evidence of suitable water supply to the Code Enforcement Officer. The evidence shall consist of the results of a primary inorganic water analysis performed upon the well to serve the structure, indicating the groundwater meets the primary drinking water standards of the Maine Rules Relating to Drinking Water for those categories tested. (§202-12F(2)(b)[4])
3. Prior to the issuance of a building permit in any approved subdivision, the subdivider shall provide the Code Enforcement Officer with a letter from a registered land surveyor stating that all monumentation shown on the plan for the lot receiving the building permit and for the approved subdivision perimeter boundaries or phase therein as approved by the Planning Board has been installed. (§202-11A(5))
4. No changes, erasures, modifications or revisions shall be made in any final plan after approval has been given by the Planning Board and endorsed in writing on the plan, unless the revised final plan is first submitted and the Board approves any modifications, except in accordance with § 202-10A(3). (§202-9C(4))
5. The approval by the Board of a subdivision plan shall not be deemed to constitute or be evidence of any acceptance by the municipality of any street, easement or other area shown on such plan. (§202-9C(5))
6. Failure to commence substantial construction of the subdivision within five years of the date of approval and signing of the plan shall render the plan null and void. (§202-9C(6))

#### **SPECIAL CONDITIONS OF APPROVAL**

1. Prior to any construction activity at the site, the applicant/developer and selected contractor shall participate in a pre-construction conference with Town and other regulatory officials to review the project's construction considerations.
2. Prior to any construction on the site, the applicant shall post a cash escrow funds or other suitable financial guarantee. The work included within this financial guaranty may include the roadway and infrastructure improvements including but not limited to utilities, drainage, lot Monumentation and As-Built Plans of the subdivision. A cash escrow fund shall also be established to cover costs for inspection services of the work associated with the roadway improvements and drainage and erosion control measures beyond the



---

# Town of Wells, Maine

## Planning Board

---

### FINDINGS OF FACTS & DECISIONS

#### Final Subdivision Application for "The Timbers"

#### Page 19 of 19

limits of the road right of way. The form and amount of this escrow must be per the approved plans and acceptable to the Town Engineer. A written Performance Guarantee Agreement shall be established between the Developer and the Town of Wells.

3. The Town of Wells, Maine may employ the services of an engineering firm to assist in the inspection of roads and other infrastructure. The cost of such additional services will be born by the developer.
4. Upon completion of construction, the applicant shall provide to the Town record as-built drawings of the roadway, drainage, lot Monumentation and utility related construction work.
5. If the Developer is found to be in default of completing any of the requirements as approved on the Subdivision Plan or in compliance with Town Ordinances, the Town shall notify the Developer in writing. The Developer shall be given 30 days to complete the required improvements. Failure to do so, shall surrender the escrow funds to the Town and give the Town full access to the escrow account funds to finish the construction. Any and all expenses incurred by the Town to complete the project shall be paid from the escrow account the Developer surrendered to the Town. The Town shall release whatever remaining escrow exists after the subdivision is completed in compliance with its approvals and after a default fine of \$1,000 is retained by the Town.

Dated at Wells, Maine this \_\_\_\_\_ day of \_\_\_\_\_, 2022

Wells Planning Board

By: \_\_\_\_\_  
Charles Millian, Chairman

DRAFT